Benjamín Rovira Guasch
Chief Executive Officer
OXIGEN Data Center S.L.
Avinguda de la Generalitat, 163-167
Sant Cugat del Vallés
Barcelona 08174
Spain

29 May 2026

Tier III Certification of Design Documents for OXIGEN Data Center S.L. – OXIGEN ODC1 in Barcelona, Spain

Dear Benjamín Rovira Guasch,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the OXIGEN Data Center S.L. – OXIGEN ODC1 as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 2 April and 27 May 2026.

This Certification recognizes that OXIGEN Data Center S.L. – OXIGEN ODC1 is capable of supporting any planned work on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier III Certification is limited by the stated total peak IT load of 1,491 kilowatts (kW). This consists of 1 data hall divided into 4 utilization zones comprising 320 kW in Zona IT 1; 385 kW in Zona IT 2; 385 kW in Zona IT 3; and 385 kW in Zona IT 4. Additionally, it consists of 8 kW in each of the non-redundant Recinto de Instalaciones de Telecomunicación Inferior (RITI) Rooms RITI 1 and RITI 2.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 29 May 2028, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,

Christopher Brown
Chief Technical Officer